

CITIZENS PROPERTY INSURANCE CORPORATION
BUILDING TYPE II AND III MITIGATION VERIFICATION AFFIDAVIT

<input type="checkbox"/>	Roof Deck Attachment <ul style="list-style-type: none"><input type="checkbox"/> Level A – Wood or Other Deck Type II only<p>Roof deck composed of sheets of structural panels (plywood or OSB). <i>Or</i> Architectural (non-structural) metal panels that require a solid decking to support weight and loads. <i>Or</i> Other roof decks that do not meet Levels B or C below.</p><input type="checkbox"/> Level B – Metal Deck Type II or III<p>Metal roof deck made of structural panels that span from joist to joist.</p><input checked="" type="checkbox"/> Level C – Reinforced Concrete Roof Deck Type, II or III<p>A roof structure composed of cast-in-place or pre-cast structural concrete designed to be self-supporting and integrally attached to wall/support system.</p>
--------------------------	--

<input type="checkbox"/>	Secondary Water Resistance N/A <ul style="list-style-type: none"><input type="checkbox"/> Underlayment<p>A self-adhering polymer modified bitumen roofing underlayment (thin rubber sheets with peel and stick underside located beneath the roof covering and normal felt underlayment) with a minimum width of 6" meeting the requirements of ASTM D 1970 installed over all plywood/OSB joints to protect from water intrusion. All secondary water resistance products must be installed per the manufacturer's recommendations. Roofing felt or similar paper based products are not acceptable for secondary water resistance.</p><input type="checkbox"/> Foamed Adhesive<p>A foamed polyurethane sheathing adhesive applied over all joints in the roof sheathing to protect interior from water intrusion.</p>
--------------------------	---

<input type="checkbox"/>	Opening Protection <ul style="list-style-type: none"><input checked="" type="checkbox"/> Class A (Hurricane Impact) – All glazed openings (windows, skylights, sliding glass doors, doors with windows, etc) less than 30 feet above grade must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the Large Missile (9 lb.) impact requirements of:<ul style="list-style-type: none"><input type="checkbox"/> SSTD12;<input type="checkbox"/> ASTM E 1886 and ASTM E 1996;<input type="checkbox"/> Miami-Dade PA 201, 202, and 203;<input checked="" type="checkbox"/> Florida Building Code TAS 201, 202 and 203.<p>All glazed openings less than 30 feet above grade shall meet the Large Missile Test standard referenced above. All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. For buildings located in the HVHZ (High Velocity Hurricane Zone) all glazed openings greater than 60 feet above grade must also meet the Small Missile Test of the respective standard.</p><input type="checkbox"/> Class B (Basic Impact) – All glazed openings (windows, skylights, sliding glass doors, doors with windows, etc) less than 30 feet above grade must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the Large Missile (4.5 lb.) impact requirements of:<ul style="list-style-type: none"><input type="checkbox"/> ASTM E 1886 and ASTM E 1996<p>All glazed openings less than 30 feet above grade shall meet the Large Missile Test standard referenced above. All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. For buildings located in the HVHZ (High Velocity Hurricane Zone) all glazed openings greater than 60 feet above grade must also meet the Small Missile Test of the respective standard.</p>
--------------------------	--

**CITIZENS PROPERTY INSURANCE CORPORATION
BUILDING TYPE II AND III MITIGATION VERIFICATION AFFIDAVIT**



CERTIFICATION

I certify that I am (**CHECK ONE OF THE FOLLOWING**):

a resident licensed General, or Building Contractor, a Licensed Building Inspector, a Registered Architect, an Engineer in the State of Florida, a Building Code Official (who is duly authorized by the State of Florida or its county's municipalities to verify building code compliance).

I also certify that I personally inspected the premises at the Location Address listed above on the inspection date provided on this Affidavit. In my professional opinion, based on my knowledge, information and belief, I certify that the above statements are true and correct.

This Affidavit and the information set forth in it are provided solely for the purpose of verifying that certain structural or physical characteristics exist at the Location Address listed above and for the purpose of permitting the Named Insured to receive a property insurance premium discount on insurance provided by Citizens Property Insurance Corporation and for no other purpose. The undersigned does not make a health or safety certification or warranty, express or implied, of any kind, and nothing in this Affidavit shall be construed to impose on the undersigned or on any entity to which the undersigned is affiliated any liability or obligation of any nature to the named insured or to any other person or entity.

Name of Company:	<u>Bennett Shuman, Architect AIA</u>	Phone:	<u>850-433-8235</u>
Name of Inspector	<u>Bennett Shuman</u> License Type <u>Architect</u>	License #	<u>FL AR 7770</u>
Inspection Date:	<u>November 13, 2013</u>		
Signature:	<u></u>	Date:	<u>Nov. 13, 2013</u> ✓
Applicant's Signature:	<u> ASSOCIATION MANAGER</u>	Date:	<u>11-13-2013</u>

“Any person who knowingly and with intent to injure, defraud, or deceive any insurer files a statement of claim or an application containing any false, incomplete, or misleading information is guilty of a felony of the third degree.”